

inches (mm)



Demersible Chopper Pumps





Model No.	Imp. Dia. inches (mm)	НР	Volt	РН	Hz	RPM	NEMA Start Code	Full Load Amps	S.F.	S.F. Amps	Locked Rotor Amps	Cord P/N ▲	Cord Size
7366*-850-66-32N	9.84 (250)	60	460	3	60	1750	Е	79.0	1.2	95.5	339.0	138319	2/4 - 18/4
7366*-850-81-32N	9.84 (250)	60	575	3	60	1750	Е	63.2	1.2	76.4	271.2	138318	6/4 - 18/4

* FOR NON-EXPLOSION PROOF (STANDARD) MODELS, USE FIGURE NUMBER 7366N.

▲ CORD SOLD SEPARATELY.

IMPORTANT!

- MOISTURE AND TEMPERATURE SENSORS **MUST** BE CONNECTED TO VALIDATE THE CSA LISTING.
- 2.) A SPECIAL MOISTURE SENSOR RELAY IS REQUIRED IN THE CONTROL PANEL FOR PROPER OPERATION OF THE MOISTURE SENSORS.CONTACT CP&S FOR INFORMATION CONCERNING MOISTURE SENSING RELAYS FOR CUSTOMER SUPPLIED CONTROL PANELS.
- THESE PUMPS ARE CSA LISTED FOR PUMPING WATER AND WASTEWATER. DO NOT USE TO PUMP FLAMMABLE LIQUIDS. NOT SUITABLE FOR ENVIRONMENTS 3.) CONTAINING GASOLINE OR HEXANE.
- INSTALLATIONS SUCH AS DECORATIVE FOUNTAINS OR WATER FEATURES PROVIDED FOR VISUAL ENJOYMENT MUST BE INSTALLED IN ACCORDANCE WITH THE NATIONAL ELECTRIC CODE ANSI/NFPA 70 AND/OR THE AUTHORITY HAVING JURISDICTION. THIS PUMP IS NOT INTENDED FOR USE IN SWIMMING POOLS, RECREATIONAL 4.) WATER PARKS, OR INSTALLATIONS IN WHICH HUMAN CONTACT WITH PUMPED MEDIA IS A COMMON OCCURRENCE.
- A NON-SPARKING BREAKAWAY FITTING MUST BE USED TO VALIDATE THE EXPLOSION PROOF LISTING
- 6.) 7.) WINDING RESISTANCE \pm 7.5%. WINDING RESISTANCE MEASURED IN OHMS @ 25°C (BETWEEN LINES) AT MOTOR LEADS PUMP RATED FOR OPERATION AT \pm 10% VOLTAGE AT MOTOR.
- - CORD SUFFIX: XF 50 FEET, XJ 75 FEET, OR XL 100 FEET. CORD SOLD SEPARATELY.
- ALL EXPLOSION PROOF PUMPS AND MOTORS ARE CSA EXPLOSION-PROOF TO CLASS I DIVSION 1 GROUPS C&D T4 RATING




A Crane Co. Company

PUMPS & SYSTEMS

SECTION 42B PAGE 59 6/19





Model No.	lmp. Dia. inches (mm)	НР	Volt	РН	Hz	RPM	NEMA Start Code	Full Load Amps	S.F.	S.F. Amps	Locked Rotor Amps	Cord P/N ▲	Cord Size
7366*-850-67-32N	10.43 (265)	75	460	3	60	1750	G	108.4	1.15	120.7	578.0	138319	2/4 - 18/4
7366*-850-82-32N	10.43 (265)	75	575	3	60	1750	G	86.7	1.15	96.6	462.4	138319	2/4 - 18/4
7366*-850-68-32N	11.42 (290)	100	460	3	60	1750	Е	136.6	1.15	155.3	578.0	138319	2/4 - 18/4
7366*-850-83-32N	11.42 (290)	100	575	3	60	1750	Е	109.2	1.15	124.2	462.4	138319	2/4 - 18/4
7366*-850-69-32N	12.21 (310)	125	460	3	60	1750	F	169.4	1.15	191.5	0.008	138320	1/0/4 - 18/4
7366*-850-84-32N	12.21 (310)	125	575	3	60	1750	F	135.6	1.15	153.2	640.0	138319	2/4 - 18/4
7366*-850-97-32N	13.39 (340)	150	460	3	60	1750	D	187.0	1.0	187.0	0.008	138320	1/0/4 - 18/4
7366*-850-1G-32N	13.39 (340)	150	575	3	60	1750	D	159.5	1.0	159.5	640.0	138320	1/0/4 - 18/4

* FOR NON-EXPLOSION PROOF (STANDARD) MODELS, USE FIGURE NUMBER 7366N.

▲ CORD SOLD SEPARATELY.


IMPORTANT!

- MOISTURE AND TEMPERATURE SENSORS **MUST** BE CONNECTED TO VALIDATE THE CSA LISTING.
- 2.) A SPECIAL MOISTURE SENSOR RELAY IS REQUIRED IN THE CONTROL PANEL FOR PROPER OPERATION OF THE MOISTURE SENSORS.CONTACT CP&S FOR INFORMATION CONCERNING MOISTURE SENSING RELAYS FOR CUSTOMER SUPPLIED CONTROL PANELS
- THESE PUMPS ARE CSA LISTED FOR PUMPING WATER AND WASTEWATER. DO NOT USE TO PUMP FLAMMABLE LIQUIDS. NOT SUITABLE FOR ENVIRONMENTS 3.) CONTAINING GASOLINE OR HEXANE
- INSTALLATIONS SUCH AS DECORATIVE FOUNTAINS OR WATER FEATURES PROVIDED FOR VISUAL ENJOYMENT MUST BE INSTALLED IN ACCORDANCE WITH THE NATIONAL ELECTRIC CODE ANSI/NFPA 70 AND/OR THE AUTHORITY HAVING JURISDICTION. THIS PUMP IS NOT INTENDED FOR USE IN SWIMMING POOLS, RECREATIONAL 4.) WATER PARKS, OR INSTALLATIONS IN WHICH HUMAN CONTACT WITH PUMPED MEDIA IS A COMMON OCCURRENCE.
- A NON-SPARKING BREAKAWAY FITTING MUST BE USED TO VALIDATE THE EXPLOSION PROOF LISTING
- WINDING RESISTANCE \pm 7.5%. WINDING RESISTANCE MEASURED IN OHMS @ 25°C (BETWEEN LINES) AT MOTOR LEADS. PUMP RATED FOR OPERATION AT \pm 10% VOLTAGE AT MOTOR.
- 6.) 7.)
- CORD SUFFIX: XF 50 FEET, XJ 75 FEET, OR XL 100 FEET. CORD SOLD SEPARATELY.
- ALL EXPLOSION PROOF PUMPS AND MOTORS ARE CSA EXPLOSION-PROOF TO CLASS I DIVSION 1 GROUPS C&D T4 RATING

SECTION 42B PAGE 60 DATE 6/19







Model No.	Imp. Dia. inches (mm)	НР	Volt	РН	Hz	RPM	NEMA Start Code	Full Load Amps	S.F.	S.F. Amps	Locked Rotor Amps	Cord P/N ▲	Cord Size
7366*-823-32-32N	9.84 (250)	25	208	3	60	1150	G	75.2	1.2	90.8	354.0	138319	2/4 - 18/4
7300 -023-32-32N	9.64 (250)	25	230	٦	00			70.8	1.2	82.6	354.0		2/4 - 10/4
7366*-823-92-32N	9.84 (250)	25	460	3	60	1150	G	35.4	1.2	41.3	177.0	138317	8/4 - 18/4
7366*-823-1B-32N	9.84 (250)	25	575	3	60	1150	G	28.3	1.2	33.0	141.6	138317	8/4 - 18/4
7366*-823-33-32N	10.02 (275)	30	208	3	60	1150	Е	90.8	1.2	114.9	354.0	138319	2/4 - 18/4
7300 -023-33-32N	10.83 (275)	30	230	l ³	60	1150		82.6	1.2	99.7	354.0	130319	
7366*-823-93-32N	10.83 (275)	30	460	3	60	1150	Е	41.3	1.2	49.9	177.0	138317	8/4 - 18/4
7366*-823-1C-32N	10.83 (275)	30	575	3	60	1150	Е	33.0	1.2	39.9	141.6	138317	8/4 - 18/4
7366*-823-49-32N	11.61 (295)	40	230	3	60	1150	Е	110.4	1.2	131.8	476.0	138319	2/4 - 18/4
7366*-823-64-32N	11.61 (295)	40	460	3	60	1150	Е	55.2	1.2	65.9	238.0	138318	6/4 - 18/4
7366*-823-79-32N	11.61 (295)	40	575	3	60	1150	Е	44.2	1.2	52.7	190.4	138317	8/4 - 18/4

* FOR NON-EXPLOSION PROOF (STANDARD) MODELS, USE FIGURE NUMBER 7366N.

▲ CORD SOLD SEPARATELY.

IMPORTANT!

- MOISTURE AND TEMPERATURE SENSORS **MUST** BE CONNECTED TO VALIDATE THE CSA LISTING.
- 2.) A SPECIAL MOISTURE SENSOR RELAY IS REQUIRED IN THE CONTROL PANEL FOR PROPER OPERATION OF THE MOISTURE SENSORS.CONTACT CP&S FOR INFORMATION CONCERNING MOISTURE SENSING RELAYS FOR CUSTOMER SUPPLIED CONTROL PANELS.
- THESE PUMPS ARE CSA LISTED FOR PUMPING WATER AND WASTEWATER. DO NOT USE TO PUMP FLAMMABLE LIQUIDS. NOT SUITABLE FOR ENVIRONMENTS 3.) CONTAINING GASOLINE OR HEXANE.
- INSTALLATIONS SUCH AS DECORATIVE FOUNTAINS OR WATER FEATURES PROVIDED FOR VISUAL ENJOYMENT MUST BE INSTALLED IN ACCORDANCE WITH THE NATIONAL ELECTRIC CODE ANSI/NFPA 70 AND/OR THE AUTHORITY HAVING JURISDICTION. THIS PUMP IS NOT INTENDED FOR USE IN SWIMMING POOLS, RECREATIONAL 4.) WATER PARKS, OR INSTALLATIONS IN WHICH HUMAN CONTACT WITH PUMPED MEDIA IS A COMMON OCCURRENCE.
- A NON-SPARKING BREAKAWAY FITTING MUST BE USED TO VALIDATE THE EXPLOSION PROOF LISTING
- 6.) 7.) WINDING RESISTANCE \pm 7.5%. WINDING RESISTANCE MEASURED IN OHMS @ 25°C (BETWEEN LINES) AT MOTOR LEADS. PUMP RATED FOR OPERATION AT \pm 10% VOLTAGE AT MOTOR.
- - CORD SUFFIX: XF 50 FEET, XJ 75 FEET, OR XL 100 FEET. CORD SOLD SEPARATELY.
- ALL EXPLOSION PROOF PUMPS AND MOTORS ARE CSA EXPLOSION-PROOF TO CLASS I DIVSION 1 GROUPS C&D T4 RATING




A Crane Co. Company

PUMPS & SYSTEMS

SECTION 42B PAGE 61 DATE 4/19





Model No.	Imp. Dia. inches (mm)	НР	Volt	РН	Hz	RPM	NEMA Start Code	Full Load Amps	S.F.	S.F. Amps	Locked Rotor Amps	Cord P/N ▲	Cord Size
7366*-823-95-32N	12.79 (325)	50	460	3	60	1150	Н	76.4	1.15	84.0	400.0	138318	6/4 - 18/4
7366*-823-1E-32N	12.79 (325)	50	575	3	60	1150	Н	61.2	1.15	67.2	320.0	138318	6/4 - 18/4
7366*-823-96-32N	13.19 (335)	60	460	3	60	1150	F	86.7	1.15	96.8	400.0	138319	2/4 - 18/4
7366*-823-1F-32N	13.19 (335)	60	575	3	60	1150	F	69.4	1.15	77.4	320.0	138318	6/4 - 18/4
7366*-823-67-32N	14.37 (365)	75	460	3	60	1150	Н	109.3	1.15	119.5	612.0	138319	2/4 - 18/4
7366*-823-82-32N	14.37 (365)	75	575	3	60	1150	Н	87.4	1.15	95.6	489.6	138319	2/4 - 18/4
7366*-823-68-32N	14.57 (370)	100	460	3	60	1150	Е	135.0	1.0	135.0	612.0	138319	2/4 - 18/4
7366*-823-83-32N	14.57 (370)	100	575	3	60	1150	Е	108.0	1.0	108.0	489.6	138319	2/4 - 18/4

* FOR NON-EXPLOSION PROOF (STANDARD) MODELS, USE FIGURE NUMBER 7366N.

▲ CORD SOLD SEPARATELY.

IMPORTANT!


- MOISTURE AND TEMPERATURE SENSORS **MUST** BE CONNECTED TO VALIDATE THE CSA LISTING.
- 2.) A SPECIAL MOISTURE SENSOR RELAY IS REQUIRED IN THE CONTROL PANEL FOR PROPER OPERATION OF THE MOISTURE SENSORS.CONTACT CP&S FOR INFORMATION CONCERNING MOISTURE SENSING RELAYS FOR CUSTOMER SUPPLIED CONTROL PANELS
- THESE PUMPS ARE CSA LISTED FOR PUMPING WATER AND WASTEWATER. DO NOT USE TO PUMP FLAMMABLE LIQUIDS. NOT SUITABLE FOR ENVIRONMENTS 3.) CONTAINING GASOLINE OR HEXANE
- INSTALLATIONS SUCH AS DECORATIVE FOUNTAINS OR WATER FEATURES PROVIDED FOR VISUAL ENJOYMENT MUST BE INSTALLED IN ACCORDANCE WITH THE NATIONAL ELECTRIC CODE ANSI/NFPA 70 AND/OR THE AUTHORITY HAVING JURISDICTION. THIS PUMP IS NOT INTENDED FOR USE IN SWIMMING POOLS, RECREATIONAL 4.) WATER PARKS, OR INSTALLATIONS IN WHICH HUMAN CONTACT WITH PUMPED MEDIA IS A COMMON OCCURRENCE.
- A NON-SPARKING BREAKAWAY FITTING MUST BE USED TO VALIDATE THE EXPLOSION PROOF LISTING
- WINDING RESISTANCE \pm 7.5%. WINDING RESISTANCE MEASURED IN OHMS @ 25°C (BETWEEN LINES) AT MOTOR LEADS. PUMP RATED FOR OPERATION AT \pm 10% VOLTAGE AT MOTOR.
- 6.) 7.)
- CORD SUFFIX: XF 50 FEET, XJ 75 FEET, OR XL 100 FEET. CORD SOLD SEPARATELY.
- ALL EXPLOSION PROOF PUMPS AND MOTORS ARE CSA EXPLOSION-PROOF TO CLASS I DIVSION 1 GROUPS C&D T4 RATING

SECTION 42B PAGE 62 DATE



A Crane Co. Company





Model No.	Imp. Dia. inches (mm)	НР	Volt	РН	Hz	RPM	NEMA Start Code	Full Load Amps	S.F.	S.F. Amps	Locked Rotor Amps	Cord P/N ▲	Cord Size
7366*-851-37-32N	10.24 (260)	10	208	3	60	870		37.2	1.2	42.0	230.0	138317	8/4 - 18/4
7300 -031-37-32N	10.24 (200)	10	230]]	00	070		38.6	1.2	42.2	230.0	130317	0/4 - 10/4
7366*-851-89-32N	10.24 (260)	10	460	3	60	870	L	19.3	1.2	21.1	115.0	138317	8/4 - 18/4
7366*-851-98-32N	10.24 (260)	10	575	3	60	870	L	15.4	1.2	16.9	92.0	138317	8/4 - 18/4
7366*-851-38-32N	11.61 (295)	15	208	3	60	870	G	50.4	1.2	59.0	230.0	138317	8/4 - 18/4
7300 -031-30-32N	11.01 (293)	13	230	ľ	00	870	G	48.4	1.2	55.6	230.0	130317	0/4 - 10/4
7366*-851-90-32N	11.61 (295)	15	460	3	60	870	G	24.2	1.2	27.8	115.0	138317	8/4 - 18/4
7366*-851-99-32N	11.61 (295)	15	575	3	60	870	G	19.4	1.2	22.2	92.0	138317	8/4 - 18/4
7366*-851-31-32N	12.99 (330)	20	208	3	60	870		69.0	1.2	76.0	400.0	138318	6/4 - 18/4
7300 -031-31-32N	12.99 (330)	20	230	l "	00	070	J	75.1	1.2	79.0	400.0	130316	0/4 - 10/4
7366*-851-91-32N	12.99 (330)	20	460	3	60	870	J	37.6	1.2	41.1	200.0	138317	8/4 - 18/4
7366*-851-1A-32N	12.99 (330)	20	575	3	60	870	J	30.1	1.2	32.9	160.0	138317	8/4 - 18/4
7366*-851-32-32N	13.78 (350)	25	208 3	60	870	Н	82.3	1.2	98.8	400.0	138319	2/4 - 18/4	
7300 -031-32-32N	13.76 (330)	23	230	l "	00	070	- ''	84.0	1.2	94.5	400.0	130319	2/4 - 10/4
7366*-851-92-32N	13.78 (350)	25	460	3	60	870	Н	42.0	1.2	47.2	200.0	138317	8/4 - 18/4
7366*-851-1B-32N	13.78 (350)	25	575	3	60	870	Н	33.6	1.2	37.8	160.0	138317	8/4 - 18/4
7366*-851-33-32N	14.37 (365)	30	208	3 60	60	870	F	98.8	1.2	124.1	400.0	138310	2/4 - 18/4
7300 -031-33-32N	14.37 (303)	30	230		0/0	Г	94.5	1.4	108.6	400.0	138319	2/4 - 10/4	
7366*-851-93-32N	14.37 (365)	30	460	3	60	870	F	47.2	1.2	54.3	200.0	138317	8/4 - 18/4
7366*-851-1C-32N	14.37 (365)	30	575	3	60	870	F	37.8	1.2	43.5	160.0	138317	8/4 - 18/4

^{*} FOR NON-EXPLOSION PROOF (STANDARD) MODELS, USE FIGURE NUMBER 7366N.

▲ CORD SOLD SEPARATELY.

IMPORTANT!

- MOISTURE AND TEMPERATURE SENSORS **MUST** BE CONNECTED TO VALIDATE THE CSA LISTING.
- 2.) A SPECIAL MOISTURE SENSOR RELAY IS REQUIRED IN THE CONTROL PANEL FOR PROPER OPERATION OF THE MOISTURE SENSORS.CONTACT CP&S FOR INFORMATION CONCERNING MOISTURE SENSING RELAYS FOR CUSTOMER SUPPLIED CONTROL PANELS.
- THESE PUMPS ARE CSA LISTED FOR PUMPING WATER AND WASTEWATER. DO NOT USE TO PUMP FLAMMABLE LIQUIDS. NOT SUITABLE FOR ENVIRONMENTS 3.) CONTAINING GASOLINE OR HEXANE.
- INSTALLATIONS SUCH AS DECORATIVE FOUNTAINS OR WATER FEATURES PROVIDED FOR VISUAL ENJOYMENT MUST BE INSTALLED IN ACCORDANCE WITH THE NATIONAL ELECTRIC CODE ANSI/NFPA 70 AND/OR THE AUTHORITY HAVING JURISDICTION. THIS PUMP IS NOT INTENDED FOR USE IN SWIMMING POOLS, RECREATIONAL 4.) WATER PARKS, OR INSTALLATIONS IN WHICH HUMAN CONTACT WITH PUMPED MEDIA IS A COMMON OCCURRENCE.
- A NON-SPARKING BREAKAWAY FITTING MUST BE USED TO VALIDATE THE EXPLOSION PROOF LISTING
- 6.) 7.) WINDING RESISTANCE \pm 7.5%. WINDING RESISTANCE MEASURED IN OHMS @ 25°C (BETWEEN LINES) AT MOTOR LEADS. PUMP RATED FOR OPERATION AT \pm 10% VOLTAGE AT MOTOR.
- - CORD SUFFIX: XF 50 FEET, XJ 75 FEET, OR XL 100 FEET. CORD SOLD SEPARATELY.
- ALL EXPLOSION PROOF PUMPS AND MOTORS ARE CSA EXPLOSION-PROOF TO CLASS I DIVSION 1 GROUPS C&D T4 RATING





A Crane Co. Company

PUMPS & SYSTEMS

SECTION 42B PAGE 63 DATE 4/19







Model No.	Imp. Dia. inches (mm)	НР	Volt	РН	Hz	RPM	NEMA Start Code	Full Load Amps	S.F.	S.F. Amps	Locked Rotor Amps	Cord P/N ▲	Cord Size
7366*-851-94-32N	14.57 (370)	40	460	3	60	870	F	62.2	1.15	69.4	275.0	138318	6/4 - 18/4
7366*-851-1D-32N	14.57 (370)	40	575	3	60	870	F	49.8	1.15	55.5	220.0	138317	8/4 - 18/4

* FOR NON-EXPLOSION PROOF (STANDARD) MODELS, USE FIGURE NUMBER 7366N.

▲ CORD SOLD SEPARATELY.

IMPORTANT!

- MOISTURE AND TEMPERATURE SENSORS **MUST** BE CONNECTED TO VALIDATE THE CSA LISTING.
- 2.) A SPECIAL MOISTURE SENSOR RELAY IS REQUIRED IN THE CONTROL PANEL FOR PROPER OPERATION OF THE MOISTURE SENSORS.CONTACT CP&S FOR INFORMATION CONCERNING MOISTURE SENSING RELAYS FOR CUSTOMER SUPPLIED CONTROL PANELS
- THESE PUMPS ARE CSA LISTED FOR PUMPING WATER AND WASTEWATER. DO NOT USE TO PUMP FLAMMABLE LIQUIDS. NOT SUITABLE FOR ENVIRONMENTS 3.) CONTAINING GASOLINE OR HEXANE
- INSTALLATIONS SUCH AS DECORATIVE FOUNTAINS OR WATER FEATURES PROVIDED FOR VISUAL ENJOYMENT MUST BE INSTALLED IN ACCORDANCE WITH THE NATIONAL ELECTRIC CODE ANSI/NFPA 70 AND/OR THE AUTHORITY HAVING JURISDICTION. THIS PUMP IS NOT INTENDED FOR USE IN SWIMMING POOLS, RECREATIONAL 4.) WATER PARKS, OR INSTALLATIONS IN WHICH HUMAN CONTACT WITH PUMPED MEDIA IS A COMMON OCCURRENCE.
- A NON-SPARKING BREAKAWAY FITTING MUST BE USED TO VALIDATE THE EXPLOSION PROOF LISTING
- WINDING RESISTANCE \pm 7.5%. WINDING RESISTANCE MEASURED IN OHMS @ 25°C (BETWEEN LINES) AT MOTOR LEADS. PUMP RATED FOR OPERATION AT \pm 10% VOLTAGE AT MOTOR.
- 6.) 7.)
- CORD SUFFIX: XF 50 FEET, XJ 75 FEET, OR XL 100 FEET. CORD SOLD SEPARATELY.
- ALL EXPLOSION PROOF PUMPS AND MOTORS ARE CSA EXPLOSION-PROOF TO CLASS I DIVSION 1 GROUPS C&D T4 RATING

SECTION 42B PAGE 64 DATE 4/19



PUMPS & SYSTEMS