



## B/W TYPE L.H. RELAY - AW21

### FEATURES

Complete installation requires two electrodes and suspension wire in addition to relay.

Electrodes AW22 - Type E-1S Brass, with plastic insulating shield  $\frac{5}{8}$ " diameter (2 required).

Suspension Wire - No.18 stranded wire with  $\frac{1}{16}$ " vinyl insulation. Sold only in 500' or 1000' rolls.

# Submersible Pump Monitoring Controls

**ORDER NUMBERS**

Relay Order No.	Volts	Rating
AW21-1	115V 1Ø	up to 1 HP*
AW21-2	230V 1Ø 230V 3Ø	
AW21-3	460V 3Ø	

\* When used with motors which exceed their ratings, controls must be wired to pilot circuit of a magnetic starter or contactor.

Order No.	Description
AW23R5	500' #18 Red Wire
AW23B5	500' #18 Black Wire
AW23R10	1000' #18 Red Wire
AW23B10	1000' #18 Black Wire
AW22	(2) Type E-1S Electrodes



Xylem, Inc.  
 2881 East Bayard Street Ext., Suite A  
 Seneca Falls, NY 13148  
 Phone: (866) 325-4210  
 Fax: (888) 322-5877  
[www.xylem.com/brands/centripro](http://www.xylem.com/brands/centripro)